

**CITY OF MIDDLETOWN  
PURCHASING DEPARTMENT**

---

**ADDENDUM #1 TO BID #2014-003**  
**HUNTING HILL DRAINAGE IMPROVEMENTS**  
**PUBLIC WORKS DEPARTMENT**  
Date Issued: March 28, 2014

**ALL BIDDERS ARE HEREBY ADVISED OF THE FOLLOWING INFORMATION AND/OR MODIFICATIONS TO THE CONTRACT BID DOCUMENTS:**

- Q & A's submitted by cutoff date of Tuesday, March 25, 2014 by 4:00 pm
- Revised Bid Proposal Pages

**INVITATION TO BID**

The date set for the receipt of proposals will remain the same.

**\*\*\*Friday, April 4 2014 at 11:00 AM\*\*\***

**PLEASE VERIFY THAT YOU HAVE RECEIVED THIS NOTIFICATION IN THE SPACE BELOW AND FAX OR EMAIL THIS PAGE BACK TO THE PURCHASING DEPARTMENT.**

**FAX: 860-638-1995 EMAIL: [purchase@middletownct.gov](mailto:purchase@middletownct.gov)**

**BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM #1: \_\_\_\_\_**  
**COMPANY NAME**

All bidders are hereby advised of the following amendments to the contract bid documents which are hereby made an integral part of the specifications for the subject project, prepared by the City of Middletown to the same extent as all other documents. All work shall conform to the standards and provisions of same. Bids submitted shall be deemed to include contract document information as shown in Addendum No. 1. General bidders shall notify sub-bidders that may be affected by this addendum as applicable. **Bidders shall be required to acknowledge receipt of this addendum in the space provided on the Bid Proposal Form on Pg. 41.**

**Failure to acknowledge receipt of this addendum by the bidder may result in the rejection of their bid.** Bidders are directed to review changes to all portions of the work as changes to one portion may affect the work of another.

**Total Addendum: 2 pages**

**\*\*\*BIDDER NOTE:** If you have already submitted a bid you shall be required to acknowledge receipt of this addendum under separate cover in a sealed envelope clearly marked with the bid number and description. This acknowledgment must be received by the time and date specified to be accepted by the City.

---

Donna L. Imme, CPPB  
Supervisor of Purchases

**Q & A For**  
**Bid # 2014-003 –HUNTING HILL DRAINAGE IMPROVEMENTS**  
**Public Works Department**

**The following questions were asked:**

1. Section 02227 Temporary pavement repair states that the thickness of the pavement is shown on the contract details. I see no such detail. What is the pavement configuration for temporary pavement?

**Temporary Pavement Repair (for same initial trenching area to be Permanently Paved), per SY, shall consist of 2" Bituminous Concrete, CI 2 on 4" Processed Aggregate Base.**

2. Under the base bid there is no bid item for permanent pavement. Will in fact permanent pavement be required and if so what is the configuration and how will we be paid for it and what will the pay width be? The alternate plan (sheet 10 of 10) shows the width of the base bid pavement to be 9'. Is this the width to be paid for under the base bid?

**The Permanent Pavement, noted as 9' for the Base Bid on details on Sheet 7 is paid for under the respective Bid Items:**

**Formation of Subgrade -SY**

**(6") Subbase - CY**

**(6") Processed Aggregate Base - CY**

**Bituminous Concrete (5") - TON**

3. In the base bid, there are 4 signs proposed. Please give locations and types/sizes.

**\*\*Please see revised bid proposal pages; item No. 23 in the base bid is eliminated.**

4. In the base bid, there are pavement markings proposed. Please give locations.

**\*\*Please see revised bid proposal pages; item No. 26 in the base bid is eliminated.**

**\*\*Also, please see revised bid proposal pages; item No. 45 in the Add Alternate 2 is eliminated**

**\*\*Please remove pages 41-48 of the bid proposal page and replace with the "Revised" bid proposal pages provided. Items 23, 26 and 45 have been eliminated and a column has been inserted to include an "extension price" for each existing item.**